

1 / 12 · Electrical Services, Service Equipment, and Separately Derived Systems

Load calculation article in the 2026 NEC?

bondingjumper.com · free TX Journeyman check

2 / 12 · Electrical Services, Service Equipment, and Separately Derived Systems

Dwelling small-appliance and laundry loads in the standard method?

bondingjumper.com · free TX Journeyman check

3 / 12 · Electrical Services, Service Equipment, and Separately Derived Systems

Four or more fastened-in-place dwelling appliances?

bondingjumper.com · free TX Journeyman check

4 / 12 · Electrical Services, Service Equipment, and Separately Derived Systems

Dwelling service conductors at 120/240 V single-phase carrying the whole load?

bondingjumper.com · free TX Journeyman check

5 / 12 · Electrical Services, Service Equipment, and Separately Derived Systems

Minimum service disconnect rating for a one-family dwelling?

bondingjumper.com · free TX Journeyman check

6 / 12 · Electrical Services, Service Equipment, and Separately Derived Systems

Clearances for overhead service conductors?

bondingjumper.com · free TX Journeyman check

2 / 12 · Electrical Services, Service Equipment, and Separately Derived Systems

1,500 VA for each small-appliance circuit (at least two) and 1,500 VA for the laundry circuit.

NEC 2026 Article 120, Part III

bondingjumper.com · free TX Journeyman check

1 / 12 · Electrical Services, Service Equipment, and Separately Derived Systems

Article 120 (it was Article 220 in earlier editions; check your 2026 index). The standard method for feeders and services is Part III.

NEC 2026 Article 120

bondingjumper.com · free TX Journeyman check

4 / 12 · Electrical Services, Service Equipment, and Separately Derived Systems

Ampacity at least 83% of the service rating.
Example: $200\text{ A} \times 0.83 = 166\text{ A}$.

NEC 2026 310.12

bondingjumper.com · free TX Journeyman check

3 / 12 · Electrical Services, Service Equipment, and Separately Derived Systems

Take 75% of their combined nameplate load (ranges, dryers, space heating and AC are figured separately).

NEC 2026 Article 120, Part III (fastened-in-place appliances)

bondingjumper.com · free TX Journeyman check

6 / 12 · Electrical Services, Service Equipment, and Separately Derived Systems

230.24: above roofs, and vertical clearance above grade by what is underneath (walkways, residential driveways, streets).

NEC 2026 230.24

bondingjumper.com · free TX Journeyman check

5 / 12 · Electrical Services, Service Equipment, and Separately Derived Systems

100 A, 3-wire.

NEC 2026 230.79(C)

bondingjumper.com · free TX Journeyman check

7 / 12 · Electrical Services, Service Equipment, and Separately Derived Systems

**Grounding electrode
conductor size?**

bondingjumper.com · free TX Journeyman check

8 / 12 · Electrical Services, Service Equipment, and Separately Derived Systems

**GEC that connects only to
ground rods?**

bondingjumper.com · free TX Journeyman check

9 / 12 · Electrical Services, Service Equipment, and Separately Derived Systems

**GEC that connects only to a
concrete-encased
electrode?**

bondingjumper.com · free TX Journeyman check

10 / 12 · Electrical Services, Service Equipment, and Separately Derived Systems

**Main bonding jumper and
supply-side bonding jumper
size?**

bondingjumper.com · free TX Journeyman check

11 / 12 · Electrical Services, Service Equipment, and Separately Derived Systems

**When does a single ground
rod need a supplemental
electrode?**

bondingjumper.com · free TX Journeyman check

12 / 12 · Electrical Services, Service Equipment, and Separately Derived Systems

**When is a metal
underground water pipe a
grounding electrode?**

bondingjumper.com · free TX Journeyman check

8 / 12 · Electrical Services, Service Equipment, and Separately Derived Systems

Not required to be larger than 6 AWG copper.

NEC 2026 250.66(A)

bondingjumper.com · free TX Journeyman check

7 / 12 · Electrical Services, Service Equipment, and Separately Derived Systems

Table 250.66, read from the largest ungrounded service-entrance conductor (or the equivalent area of parallel sets).

NEC 2026 250.66; Table 250.66

bondingjumper.com · free TX Journeyman check

10 / 12 · Electrical Services, Service Equipment, and Separately Derived Systems

Table 250.102(C)(1), read from the size of the service conductors.

NEC 2026 250.28; Table 250.102(C)(1)

bondingjumper.com · free TX Journeyman check

9 / 12 · Electrical Services, Service Equipment, and Separately Derived Systems

Not required to be larger than 4 AWG copper.

NEC 2026 250.66(B)

bondingjumper.com · free TX Journeyman check

12 / 12 · Electrical Services, Service Equipment, and Separately Derived Systems

When at least 10 ft is in direct contact with the earth. It always needs a supplemental electrode.

NEC 2026 250.52(A)(1); 250.53(D)

bondingjumper.com · free TX Journeyman check

11 / 12 · Electrical Services, Service Equipment, and Separately Derived Systems

Always, unless that one rod measures 25 ohms or less to earth. Two rods are at least 6 ft apart.

NEC 2026 250.53(A)

bondingjumper.com · free TX Journeyman check